

UNIFORM CONSTRUCTION CODE NJAC 5:23-6.8
REHABILITATION SUBCODE

(d) Electrical Materials and Methods

EXCEPTIONS to the Electrical Subcode (N.J.A.C. 5:23-3.16)

110.8 – Wiring Methods.

110.26 – Spaces About Electrical Equipment 600 Volts or less.

110.32 – Work Space About Equipment over 600 Volts not upgraded.

110.33 – Entrances to Enclosures and Access to Working Space.

210.11 – Branch Circuits Required.

210.12 – Arc-Fault Circuit-Interrupter Protection.

210.52 – Dwelling Unit Receptacle Outlets.

210.60 – Guest Rooms or Guest Dormitories.

210.62 – Show Windows.

210.63 – HVACR Equipment Outlet.

210.70 - HVACR Lighting Outlets.

680.26(B)(2) – Equipotential Bonding of existing paved surfaces/decks.