

**TITLE 5. COMMUNITY AFFAIRS**  
**CHAPTER 23. UNIFORM CONSTRUCTION CODE**  
**SUBCHAPTER 6. REHABILITATION SUBCODE**  
*N.J.A.C. 5:23-6*

**(d) Electrical Materials and Methods.** The following sections of the electrical subcode (*N.J.A.C. 5:23-3.16*) shall constitute the electrical materials and methods requirements for this subchapter:

1. Section 90.7, entitled "Examination of Equipment for Safety" of the Introduction, Article 90;
2. All of Chapter 1 entitled "General" except Sections 110.8 Wiring Methods, 110.26 Spaces About Electrical Equipment (600 Volts, Nominal, or less), 110.32 Work Space About Equipment (over 600 Volts, Nominal) and 110.33 Entrance and Access to Work Space;
  - i. Section 110.32 shall be required for equipment upgrades (increase in total voltage);
3. All of Chapter 2 entitled "Wiring and Protection" except Sections 210.11 Branch Circuits Required, 210.52 Dwelling Unit Receptacle Outlets, 210.60 Guest Rooms or Guest Suites, 210.62 Show Windows, 210.63 Heating, Air Conditioning, and Refrigeration Equipment Outlet and 210.70 Lighting Outlets Required;
4. All of Chapter 3 entitled "Wiring Methods and Materials";
5. All of Chapter 4, entitled "Equipment for General Use" except Section 404.8 Accessibility and Grouping (switches) and Section 408.18 Clearances (switchboards and panelboards);
6. All of Chapter 5, entitled "Special Occupancies;"
7. All of Chapter 6, entitled "Special Equipment;"
8. All of Chapter 7, entitled "Special Conditions;" and
9. All of Chapter 8 entitled "Communications Systems."
10. Existing working clearances, clear space, access and entrance dimensions to working spaces, illumination, headroom clearances, and location of overcurrent protection devices shall be allowed to remain without modification.